

## NOTICE TO BIDDERS

Faulkner County will be accepting sealed bids on one or more Water Storage Tank(s).

Bid specifications and Submittal forms may be obtained from the Faulkner County Judge's Office. Bids will be accepted until 9:00 am on Wednesday, July 24, 2019, at which time they will be opened at the Faulkner County Judge's Office, located at 801 Locust Street Conway AR, 72034. Faulkner County reserves the right to accept or reject any or all bids placed and waive formalities.

Bids should be submitted in total including taxes, for the price to be paid by Faulkner County.

Direct questions and requests for clarifications related to this RFP to Angie Wooley at 501-450-4914.

Bids may be mailed to:

Faulkner County  
Attn: Water Storage Tank(s)  
801 Locust Street  
Conway AR, 72034

BID INFORMATION AND BID SPECIFICATIONS

FOR

CONTRACTOR BIDDING PROJECT

THIS BID PACKET CONTAINS INFORMATION  
CONCERNING PROJECT FOR  
FAULKNER COUNTY, ARKANSAS  
COUNTY JUDGE JIM BAKER

One or More Water Storage Tanks

July 9, 2019

Faulkner County, Arkansas

Water Storage Tank(s)

Date: July 9, 2019

Reference: Water Storage Tank(s)

Bid is to be addressed to:

Faulkner County  
Attn: Water Storage Tank(s)  
801 Locust Street  
Conway, Arkansas 72034

**BIDS ARE DUE ON Wednesday, July 24, 2019 by 9:00 A.M.**

Bids may be mailed or hand delivered to Judge Jim Baker, County Judge, Faulkner County, Arkansas. All bids must be turned in prior to the **9:00 AM** deadline.

\*\*\*\*\*Faxed, Phone, or e-mail bids will not be accepted.

\*\*\*\*\*All bids must be in a sealed envelope and marked Attn: Water Storage Tank(s)

Water Storage Tank Specifications

- 335 Gallon
- 160 PSI ASME
- Vertical
- Manhole 11" x 15"
- Angle Iron Legs
- Glass Lining
- Threaded Openings-3" Supply/Return, 1" T&P Relief, 1 ¼ " Drain
- Five Year Limited Warranty
- Magnesium Anodes
- Primer Finish

Scope of Work:

Bidder must provide labor and materials required to:

- Remove and dispose of existing tanks
- Rigging and placement of new tanks
- Install new pipe and fittings to connect new tanks to existing water piping
- Install insulation on new tanks
- Testing of new storage tanks and flow
- Includes one year warrant on all work performed

- Bidders shall submit their bids on the form supplied by the Judge's Office.

# Bid

Name of Dealer \_\_\_\_\_

Name of Individual Representing Dealer \_\_\_\_\_

The above named dealer offers to sell one or more water storage tank(s) with the following specifications

- 335 Gallon
- 160 PSI ASME
- Vertical
- Manhole 11" x 15"
- Angle Iron Legs
- Glass Lining
- Threaded Openings-3" Supply/Return, 1" T&P Relief, 1 ¼ " Drain
- Five Year Limited Warranty
- Magnesium Anodes
- Primer Finish

Scope of Work:

Bidder must provide labor and materials required to:

- Remove and dispose of existing tanks
- Rigging and placement of new tanks
- Install new pipe and fittings to connect new tanks to existing water piping
- Install insulation on new tanks
- Testing of new storage tanks and flow
- Includes one year warrant on all work performed

to Faulkner County, at a base price of \_\_\_\_\_.

Total bid price: \_\_\_\_\_.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Name: \_\_\_\_\_